

TEST REPORT

250720 / 2

Date received: 07/05/18
Date of test: 07/05/18
Date of issue: 11/06/18

COSMO TECHNOLOGY S.R.L.
VIA ANTONIO DURANTE, 42
33080 PRATA DI PORDENONE (PN)
ITALIA

Sample name: Rif. 3 COSMOPEX sp. 10 mm HPL 0,9 mm (2 lati)

Cold-check test PTP 154:2016 Rev. 0

Procedure:

The test has been carried out putting the sample in a forced ventilation climatic chamber, at the following conditions:

4 hours at 60 ± 3 °C

4 hours at -20 ± 3 °C

Test results:

N. of cycles	Remarks
15	At the end of testing no defects have been found.

This document is validated by digital signature and time stamping in accordance with the Italian laws and the European Directives which regulate the electronic signature systems.

Managing Director
Dr. Andrea Giaven

The sample name and, when relevant, its description, are given by the orderer, and CATAS does not assume responsibility on this matter. This test report relates to the sample submitted for the test and no others. Additions, deletions or alterations are not permitted. This test report must always be reproduced in its entirety. Unless otherwise stated, sampling has been carried out by the orderer.